



AQUA ENVIRONMENTAL LAB

56 Church Hill Road • Newtown, CT 06470 • (203) 270-9973

Report of Analysis

Name: Sywal Corporation
 Camp Playland & Playland Nursery School
 800-802 Ponus Ridge Road
 New Canaan, CT 06840

Sample ID#: 194495
Sample Type: Drinking Water
Sample Source: Office Kitchen
Sampler: PT
PWS ID: CT1350013

Sample Date: 2/2/2017 12:30 PM
Receipt Date: 2/2/2017 4:00 PM
Report Date: 2/3/2017
Sample Site: DISTRIBUTION SYSTEM

Parameter	Sample Result	Units	Method	Minimum Detection Level	Analysis Date	Analyst
Biological						
Coliform Bacteria	absent	none	SM9223B	0	2/2/2016	KH
e Coli Bacteria	absent	none	SM9223B	0	2/2/2016	KH
Inorganic Compounds						
Chlorine, residual	ND	mg/L	SM4500CLG	0.05	2/3/2017	KH
Physical						
Color	<5	CU	EPA 110.2a	0	2/3/2017	KH
Odor	0	0-5 Scale	SM2150B	0	2/2/2017	KH
PH	7.31	SU	SM4500HB	0	2/3/2017	KH
Turbidity	0.10	NTU	EPA 180.1	0.05	2/3/2017	KH

Comments: Samples were collected in accordance with the NE States Sample Collection Manual Rev 5.0

ND = Not Detected * = Above Specified Limit
--

Report Approved by:  CT Lic PH-0787 NY Lic 11706
 Lab Director

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.